LEE, KURT R GS-13 USAF AFMC AFCEC/CZRW Kesin Anderson Albert Tripp: CONNALLY, MARC B GS-12 USAF, Airway Heights Wells Preliminary Results Tuesday, May 16, 2017 10:39:18 AM

As discussed a moment ago, this morning we received preliminary results for the samples taken from three Airway Heights system wells. Two have PFOS/PFOA levels above the EPA Lifetime Health Advisory of 70 ppt (ng/l). The Park West well result was non-detect. Results summarized

Well Number	Well Owner	Phone Number	Address	Notes	Date Sampled	Date Samples Shipped to Lab	Results Due	Lab Result - PFOS (ng/L)	Lab Result - PFOA (ng/L)	PFOS ExceedsHA	PFOA Exceeds HA	PFOA+ PFOS Exceeds HA
Airway Heights #9	Airway Heights	Kevin Anderson: 509-244-5429	12400 W. 21st Ave	public supply well, Well #9	5/8/2017	5/9/2017	5/16/2017 12:00	1200	320	YES	YES	YES
Airway Heights Park West	Airway Heights	Kevin Anderson: 509-244-5429		public supply well, Park West	5/9/2017	5/9/2017	5/16/2017 12:00	ND(10)	ND(10)	NO	NO	NO
Airway Heights Well P-1/4	Airway Heights	Kevin Anderson: 509-244-5429	12400 W. 21st Ave	public supply well, Wells #1 and #4 (combined)	5/8/2017	5/9/2017	5/16/2017 12:00	1100	300	YES	YES	YES

We will have the lab data packages and results fully validated in 2-3 weeks. We have been taking mitigation action on preliminary results for our private well sample effort, since the numbers are unlikely to change significantly during validation.

Please let me know if you have any questions. Will follow shortly with a meeting invite to discuss further with team.

//SIGNED// Kurt Lee, GS-13, DAF Air Force Civil Engineer Center (AFCEC) Phone: 210-395-0541/DSN: 969-0541